



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	6-14-06	Interpretation #	06-010
Topic	Smoke Barriers		
Code Section(s)	2001 California Building Code, Sections 310.1, 308.2.2.1& 905.2.3		
Requested by	Gregg T. Wanke Oakmont Senior Living 220 Concourse Blvd. Santa Rosa, CA 95403		

### ***R2.1 fully sprinklered TYPE V-1hr.***

#### ***Is a smoke barrier required to continue thru the attic space to the roof sheathing?***

Yes. A smoke barrier shall be continuous from floor to floor or roof above, through all concealed spaces including suspended ceilings, interstitial structural and mechanical spaces. Where installed to sub-divide the attic area, the smoke barrier shall terminate at the underside of the roof sheathing, deck or slab.